



Athens-Clarke County
PUBLIC UTILITIES DEPARTMENT
Cross Connections
Final Inspection Checklist



Developer Name: _____

Date of Final Inspection: _____

| ITEM NO. 1: BFP Type | Completed |
|--|------------------|
| 1. All BFP types shall be approved by the Cross Connection Coordinator based on level of hazards or contaminates that will be present on site. | |
| ITEM NO. 2: BFP Installation | |
| 2. All in ground assemblies shall be in an oversized enclosure with a gravel bottom. | |
| 3. All above ground assemblies shall be installed in an insulated, stainless steel, secure enclosure with a properly sized concrete pad. | |
| 4. Enclosures installed in landscaping must be installed 1 to 2 inches above final grade. | |
| 5. Enclosures shall not be installed in the sidewalks, unless approved by the Cross Connection Coordinator. | |
| 6. All enclosures shall be free of any debris. | |
| 7. All concrete enclosures shall have steps, 3x3 aluminum hatch, and a gravel bottom. | |
| 8. No assemblies shall be installed in a ceiling or no higher than 3 feet off the floor. | |
| 9. All assemblies shall have a passing test and the reports sent to the Cross Connection Coordinator before the Certificate of Occupancy will be issued. | |
| 10. All above ground enclosures shall be a stainless-steel enclosure. The enclosure shall be secure, have an access panel and be mounted to a properly sized concrete pad. | |
| ITEM NO. 3: Certificate of Occupancy | |
| 11. All BFP's shall have a passing test report. | |
| 12. All enclosure installations shall be inspected and approved. | |
| 13. The test reports shall be submitted to the Cross Connection Control Office. | |
| ITEM NO. 4: Miscellaneous | |
| 14. Area free of debris. | |
| 15. Area grassed and mulched where necessary. | |
| 16. Elevation and grade conformity to approved construction plans. | |

The above is not an all-inclusive list but was created to help guide an applicant through the inspection process. Project specific details may vary.