

**ATHENS-CLARKE COUNTY
J.G BEACHAM WATER TREATMENT PLANT
800 WATERWORKS DRIVE
ATHENS, GEORGIA 30601
PHONE: (706) 613-3481 FAX: (706) 613-3477**

ROUTINE TAP WATER ANALYSIS

QUARTER: FIRST QUARTER

LABORATORY I.D. NUMBER :	<u>001</u>	SAMPLE SITE :	<u>OPERATOR'S LABORATORY</u>
REPORT NUMBER :	<u>1</u>	DATE SAMPLED :	<u>1/6/2014</u>
ANALYZED BY :	<u>RAFAEL R. MÉNDEZ</u>	DATE RECEIVED :	<u>1/6/2014</u>
COLLECTED BY :	<u>RAFAEL R. MÉNDEZ</u>	DATE REPORTED :	<u>1/8/2014</u>

THE WATER WAS ANALYZED ACCORDING TO "STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER" LATEST EDITION, APHA, AWWA, AND WPCF.

RESULTS

RESULTS EXPRESSED IN MG/L UNLESS INDICATED OTHERWISE

pH	<u>7.30 SU</u>	TOTAL PHOSPHATE	<u>0.72</u>
ALKALINITY	<u>26</u>	HETEROTROPHIC PLATE COUNT	<u>0 CFU'S</u>
CONDUCTIVITY	<u>126.1</u>	CHLORINE	<u>1.60</u>
TOTAL DISSOLVED SOLIDS	<u>62.6</u>	POTASSIUM	<u>2.4</u>
ALUMINUM	<u>0</u>	TONS	<u>0</u>
TOTAL HARDNESS	<u>48</u>	FLUORIDE	<u>0.77</u>
NITROGEN NITRATE	<u>2.0</u>	CALCIUM	<u>10.4</u>
NITROGEN AMMONIA	<u>0</u>	CALCIUM HARDNESS	<u>26</u>
COLIFORM BACTERIA	<u>0</u>	MAGNESIUM	<u>5.4</u>
TEMPERATURE	<u>13.5 C</u>	pHS	<u>9.84</u>
CARBON DIOXIDE	<u>12.5</u>	LANGEIER INDEX	<u>-2.54</u>
MANGANESE	<u>0.012</u>	IRON	<u>0.032</u>
LEAD	<u>0.0025</u>	SODIUM	<u>2.44</u>
COPPER	<u>0.0740</u>	HYDROGEN SULFIDE	<u>0</u>
ZINC	<u>0.200</u>	TRIHALOMETHANES	<u>0.072</u>
CHLORIDE	<u>13</u>	SULFATE	<u>7.20</u>
TURBIDITY	<u>0.13NTU'S</u>		