

NOTE:

1. BACKFLOW DEVICES AND VAULTS PER ACC BACKFLOW PROGRAM.
2. ALL APPLICABLE NFPA REQUIREMENTS APPLY.
3. NO PIV'S ON PUBLIC WATER MAINS.
4. WHERE RIGHT OF WAY IS NOT SUFFICIENT, MINIMUM 20' WIDE EASEMENT IS REQUIRED.
5. CONTRACTOR TO PROVIDE WATER SERVICES WHEN INSTALLATION OCCURS AS PART OF A WATER MAIN EXTENSION.

Fire and Domestic Service Detail

NTS

W-11

Standard Specification and Detail for:

Fire and Domestic Service Detail

GMD: NA

County: Athens-Clarke

State: Georgia

Date: June, 2025

Drawn by: KFM

Approved by: MRA

Scale: AS-SHOWN

The Unified Government of Athens-Clarke County

Department of Public Utilities

124 E Hancock Ave

Athens, Georgia 30601

Voice: 706-613-3490

