



Athens-Clarke County
Public Utilities Department
FOG Plans Review Checklist



Plans Review Checklist	OK	Absent
1) Food Service Establishments that discharge to Publicly Owned Treatment Works (POTW) are required to have a grease removal system.		
2) A. Outdoor underground grease interceptors are required and shall have a minimum capacity of 1,500 gallons and a sample manhole on the outlet side of the interceptor. This sample manhole shall have a minimum diameter of 10" B. If space limitations do not permit an outdoor interceptor, indoor interceptors may be used pending an approved variance issued by the ACC Public Utilities Department. Indoor traps shall have minimum capacity of 40 pounds.		
3) Plumbing lines from grease interceptor outlet shall be 6" from outlet to Point of Connection with sanitary sewer.		
4) Detail sheet showing A.C.C. grease trap diagram.		